

ONCOR ELECTRIC DELIVERY POOL REQUIREMENTS

Effective April 1, 2005. Pool plans located in Metro West cities (Lakeside is a “Metro West City”) will be approved by Byron Spencer at the Arlington Service Center located at 2118 S. Bowen Road, Arlington, TX 76013. Plans can be mailed with a self-addressed stamped return envelope to Mr. Spencer’s attention at this address and will be returned to you upon review completion.

The following guidelines will be required in order to obtain an ONCOR Electric Delivery approval stamp on all swimming pools and all other water features.

It is the responsibility of the pool company digging the pool or other water feature to call Texas Excavation Safety System (TESS) at 1-800-344-8377 and request a locate before pool plans are submitted. If excavation begins fourteen (14) days after the initial locates, the pool company may be obligated to request a new locate pursuant to the applicable legal authorities. This request must include locates for all electrical facilities including primary, secondary, service, and street light facilities either direct buried or in conduit. These facilities must be marked in red and drawn to scale on all three (3) sets of plans that are required to be submitted to ONCOR Electric Delivery for approval. The location of the electric meter must be shown on the house. Any overhead electrical lines within thirty (30) feet of the water’s edge must also be shown and drawn to scale. Plans must include water feature, associated decking and walkways. The TESS confirmation number must be listed on the pool plans.

Along with three sets of pool plans, it is required that the pool builder supply a copy of the final survey for the lots showing all property lines and any easements located within the property. If the pool is being built on a new construction site, a copy of that portion of the Final City Plat showing the address will be accepted. The clearing of easements and right-of-way is the responsibility of the pool company. Decking or permanent structure will be prohibited over existing direct buried service. In these cases, a service reroute will be required. NO ENCROACHMENTS INTO EXISTING EASEMENTS WILL BE ALLOWED.

The pool company will be provided with a form Indemnity and Release regarding the accuracy and completeness of the information provided to ONCOR Electric Delivery for the approval of pool plans or other water features. This completed and signed document, WITH ORIGINAL SIGNATURE, must be attached to the pool plans when submitted for approval. Failure to provide a signed copy of this document will delay the approval of pool plans.